



# Punjab Fire Services (Kotakpura)



## FIRE SAFETY CERTIFICATE ਫਾਇਰ ਸੇਫਟੀ ਪ੍ਰਮਾਣ ਪੱਤਰ

NOC No **4020-97606-Fire/73912**

NOC Type: **Renew**

Dated **18-Aug-2024**

Certified that the **CLS DAV CENT PUBLIC SCHOOL** at **DAV CENT PUBLIC SCHOOL, BATHINDA ROAD, JAITO** comprised of **0** basements and **3** (Upper floor) owned/occupied by **MOHIT GROVER** have complied with the fire prevention and fire safety requirements of National Building Code and verified by the officer concerned of fire service on **17-Aug-2024** in the presence of **MOHIT GROVER** (Name of the owner or his representative) and that the building / premises is fit for occupancy group **B** subdivision **B1** (As per NBC) for period of **one year** from issue date. Subject to the following conditions.

Issued on **18-Aug-2024** at **Kotakpura**

ਤਸਦੀਕ ਕੀਤਾ ਜਾਂਦਾ ਹੈ ਕਿ **CLS DAV CENT PUBLIC SCHOOL** ਜੋ ਕਿ **DAV CENT PUBLIC SCHOOL, BATHINDA ROAD, JAITO** ਸਮੇਤ **0** ਬੇਸਮੈਂਟ ਅਤੇ **3** (ਉੱਪਰਲੀ ਮੰਜ਼ਿਲ) ਮਲਕੀਅਤ/ਕਾਬਜ਼ਦਾਰ **MOHIT GROVER** ਨੂੰ ਅੱਗ ਬੁਝਾਉਣ ਦੇ ਪ੍ਰਭਾਵੀ ਅਤੇ ਬਚਾਅ ਦੇ ਰਾਸ਼ਟਰੀ ਬਿਲਡਿੰਗ ਕੋਡ ਅਨੁਸਾਰ ਜਿਸ ਨੂੰ ਸਬੰਧਤ ਅੱਗ ਬੁਝਾਉ ਅਧਿਕਾਰੀ ਵੱਲੋਂ ਪ੍ਰਮਾਣਿਤ ਕੀਤਾ ਗਿਆ **17-Aug-2024** ਮੌਜੂਦਗੀ ਵਿੱਚ **MOHIT GROVER** (ਮਾਲਕ ਦਾ ਨਾਮ ਜਾਂ ਉਸ ਦਾ ਪ੍ਰਤੀਨਿਧੀ) ਅਤੇ ਇਮਾਰਤ / ਬਿਲਡਿੰਗ ਆਬਾਦੀ ਲਈ ਯੋਗ ਹੈ। Occupancy Group **B** subdivision **B1** (ਐਨ. ਬੀ. ਸੀ. ਦੇ ਅਨੁਸਾਰ) ਦੇ ਪ੍ਰਭਾਵੀ ਸਮੇਂ ਤੋਂ **ਇੱਕ ਸਾਲ** ਤੱਕ। ਜਿਸ ਲਈ ਨਿਮਨ ਅਨੁਸਾਰ ਹਦਾਇਤਾਂ ਹਨ।

ਜਾਰੀ ਕਰਨ ਦੀ ਮਿਤੀ **18-Aug-2024** ਕਿੱਥੇ **Kotakpura** .

1. Fire Safety arrangements shall be kept in working condition at all the times.  
ਹਰ ਸਮੇਂ ਅੱਗ ਤੋਂ ਬਚਾਅ ਦੇ ਯੰਤਰਾਂ ਨੂੰ ਚਾਲੂ / ਚੰਗੀ ਹਾਲਤ ਵਿੱਚ ਰੱਖਿਆ ਜਾਵੇ।
2. No, alteration/ addition/ change in use of occupancy is allowed.  
ਕਿਸੇ ਵੀ ਤਰ੍ਹਾਂ ਦੇ ਬਦਲਾਅ/ ਵਾਧੇ/ ਕਾਬਜ਼ਕਾਰ ਵਿੱਚ ਬਦਲਾਵ ਦੀ ਮਨਾਹੀ ਹੈ।
3. Occupants/ owner should have trained staff to operate the operation of fire safety system provided there in.

ਉਪਲੱਬਧ ਅੱਗ ਬੁਝਾਉਣ ਦੇ ਯੰਤਰਾਂ ਦੀ ਵਰਤੋਂ ਤੋਂ ਰਹਿਣ ਵਾਲੇ ਲੋਕਾਂ / ਮਾਲਕਾਂ ਨੂੰ ਜਾਣੂੰ ਕਰਵਾਇਆ ਜਾਣਾ ਯਕੀਨੀ ਬਣਾਇਆ ਜਾਵੇ।

4. Fire Officer can check the arrangements of fire safety at any time, this certificate will be withdrawn without any notice if any deficiency is found.

ਫਾਇਰ ਬਿਗਰਡ ਅਧਿਕਾਰੀ ਕਿਸੇ ਵੀ ਵਕਤ ਇਨ੍ਹਾਂ ਸਾਰੇ ਪ੍ਰਬੰਧਾਂ ਨੂੰ ਚੈੱਕ ਕਰ ਸਕਦਾ ਹੈ, ਜੇ ਕਰ ਕੋਈ ਕਮੀ ਪਾਈ ਗਈ ਤਾਂ ਬਿਨਾਂ ਕਿਸੇ ਨੋਟਿਸ ਦੇ ਇਹ ਸਰਟੀਫਿਕੇਟ ਰੱਦ ਸਮਝਿਆ ਜਾਵੇਗਾ।

5. Occupants/ owner should apply for renewal of fire safety certificate one month prior to expiry of this certificate.

ਮਾਲਕ ਜਾਰੀ ਕੀਤੇ ਗਏ ਫਾਇਰ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਦੀ ਮਿਤੀ ਖਤਮ ਹੋਣ ਤੋਂ ਇੱਕ ਮਹੀਨਾ ਪਹਿਲਾਂ ਰੀਨੀਊ ਕਰਵਾਉਣ ਲਈ ਪਾਬੰਦ ਹੋਵੇਗਾ।

**\* Above Details cannot be used as ownership proof.**

ਉਪਰੋਕਤ ਦਰਸਾਈ ਗਈ ਜਾਣਕਾਰੀ ਨੂੰ ਮਾਲਕਾਨਾ ਦੇ ਸਬੂਤ ਵਜੋਂ ਨਹੀਂ ਵਰਤਿਆ ਜਾਵੇਗਾ।

\* This is digitally created certificate, no signature are needed

ਇਹ ਡਿਜੀਟਲੀ (ਕੰਪਿਊਟਰਾਈਜ਼ਡ) ਤਿਆਰ ਕੀਤਾ ਗਿਆ ਸਰਟੀਫਿਕੇਟ ਹੈ, ਜਿਸ ਵਿੱਚ ਦਸਤਖਤ ਦੀ ਕੋਈ ਲੋੜ ਨਹੀਂ ਹੈ।

**Inspection Report by Fire Officer**

**PROFORMA FOR INSPECTION REPORT REGARDING PREVENTION OF FIRE & SAFETY MEASURES.**

(High rise/multistory buildings, hospital, nursing homes, corporate offices, factories and Hazardous storages)

		Date of inspection.....17/08/2024
Sr. No.	Detail of Building/Premises	Detail of the Building/Premises/ Fire safety Measures.
1	Name of the building /premises (Location/ Address)N.	CLS DAV CENT PUBLIC SCHOOL -BATHINDA ROAD, JAITO
2	Name of the address of the owner with contact no.	DAV COLLEGE TRUST AND MANAGMENT COMMATE - CHITRA GUPTA ROAD, PAHARGANJ, NEW DELHI
3	Name & Address of the occupier with contact no	MOHIT GROVER - HALWAIYAN WALI GALI,NEAR NEW BUS STAND KOTKAPURA- 9781349258
4	Total area of the premises	8296
5	Total covered area	1670
6	Height of the building from the ground level.	10
7	Number of basements & its area	NA
8	Number of sanctioned floors	G+2
9	Number of actual floors	G+2
10	Parking area.	INSIDE THE PREMISES
11	Detail of surrounding properties Left Right Front Back	AS PER SUBMITTED BY APPLICANT IN ONLINE APPLICATION
12	Number of main gate with size.	15 FT WIDTH OF MAIN GATE
13	No of fire extinguisher installed in the building on each floor with capacity, type with ISI marking number and date of manufacturing	13 ABC FIRE EXTINGUISHERS CAPACITY 4 AN 5 KG AND 02 CO2 FIRE EXTINGUISHERS CAPACITY 4.5 KG ISI MARKED
14	Detail of Hose reel on each floor indicating size & length of rubber pipe	ONE HOSEREEL AT EACH FLOOR WITH STANDARD SIZE AND LENGTH
15	Detail of wet riser, No. of landing valve delivery hose, pipe & hose cabinet on each floor	NA
16	No. of yard Hydrant, with detail	ONE POINT AT GROUND FLOOR WITH HOSE AND BRANCH OF STANDARD SIZE AND LENGTH
17	Whether basement is being used for parking, storage or office. Has the basement sprinkler system , Give all detail.	NA
18	No. of manual fire alarms installed in the building.	NA
19	Detail of automatic fire detection system P.A. system provided in the building.	PA SYSTEM PROVIDED

20	Detail of control panel.	NA
21	Details of water storage capacity underground/overhead with size of tank.	5000
22	Detail of pumps with head and make a) Main Pump b) Jockey Pump:- c) Diesel Pump:-	450 LPM
23	Position of fire service inlet (2way, 3way, 4way)	NA
24	No. of stair cases with size.	TWO STAIR CASE
25	No. of lift and ramps with details of communication system.	NA
26	Details of mean of escape	STAIRS AND DOORS
27	Stand by source of power supply with all details of	GEN SET



Error

Failed to load PDF document.

Reload

**Print**

**Print Certificate**

**Please Download and keep the print of Inspection Report and Owner's Checklist also,  
These documents should be produced on demand along with NOC**